

C-65



COCHIN PORT TRUST

Phone : 91 0484 2666639
: 91 0484 2582300/2582305

**OFFICE OF THE
CHIEF MECHANICAL ENGINEER**

No. F1/T-8/UTL-Shorepower-PhII/2019-M

Dated: 19.08.2019

Clarification-5 & Tender Extension Notice

Sub: Providing Shore power to the vessels calling at UTL & nearby berths in Cochin Port- Phase II - Clarification-Reg.

Ref: This office Notice Inviting Tender of even No. dated 13.06.2019.

The following amendment is made in the tech specification for the subject work

Item	Query	Reply by CoPT
Sec IV. 1.8 & 1.8.1 of Technical Specification	Core Material shall be CRGO - Amorphous. Please confirm whether the core material shall be CRGO or Amorphous material. In Revised Approved make list, most of approved vendors are not manufacturing the amorphous material for core and thus they have regret the offer for 1250 kVA & 630 kVA transformer.	The core material may be either CRGO or Amorphous

The due date of submission & opening of subject tender is hereby extended to 31.08.2019 at 15.00 hrs & 15.30 hrs respectively.

For further details please log on to www.tenderwizard.com/COPT. This extension notice will form the part of Tender document

V. Thiruvandian
19/8/19
Chief Mechanical Engineer
Amey