**RECORD NOTE OF PRE BID MEETING (HYBRID MODE)
HELD AT 11:00 HOURS ON 05-10-2026 REGARDING
"RECONSTRUCTION OF ROADS WITH CC PAVER BLOCKS AND
CONSTRUCTION OF RCC DRAINS AT SER AREA OF W/ISLAND"
(Tender No.T10/T-2113/2026-C)**

1. The following officials of Cochin Port Authority were present in the pre-bid meeting:

    (i) Shri. Thadevus T.P, Dy. Chief Engineer(I)
    (ii) Smt. Anjana N, Executive Engineer(I)
    (iii) Shri. Siji. C. Mathew, Asst. Engineer (Tech)

2. The meeting in hybrid mode commenced at 11:00 Hrs. But, no bidders were participated in the meeting.

3. However, one written query was received from a prospective bidder. The Department's reply to the query is attached below.

4. The meeting concluded by 11:10 Hrs.

Sd/-

Dy. Chief Engineer-I

ADDENDUM / CORRIGENDUM NO.2

COCHIN PORT AUTHORITY
An ISO-9001 & ISPS Compliant Port

Phone: 91484 2666414
E-mail : ce@cochinport.gov.in, coptce@gmail.com
Website: www.cochinport.gov.in

CHIEF ENGINEER'S OFFICE
COCHIN-682009

TENDER FOR
"RECONSTRUCTION OF ROADS WITH CC PAVER BLOCKS AND CONSTRUCTION OF RCC DRAINS AT SER AREA OF W/ISLAND"
(Tender No. T10/T-2113/2026-C)

BIDDER'S QUERIES AND RESPONSE OF THE DEPARTMENT

Sl. No.	Section / Clause / Sub Clause No.	Tender Specification	Queries from Bidder	Response of CoPA
1	Section -I Sl. No.15 under 5-Contract Data	The Defects Liability Period is One year from the date of completion of the work.	Road from M/s. Konken Storage to M/s. Josco Automobiles: Since the sub soil is very week and without any soil improvement or ground treatment, if the road formation and tile laying is done, when the movement of loaded trucks, it may settle within no time.	Please see **Addendum / Corrigendum No.3.**
2	Schedule -II Sl. No.7, under Part – C.	Supplying and stacking good quality cut gravel / red earth as per detailed specifications and directions of the Engineer-in-Charge.	Supply and stacking of good quality earth only specified, laying and compacting procedure is not explained in BOQ. Since roller compaction will not be possible by dumping the earth over untreated base soil.	(i) Spreading of stacked earth shall be operated under item No.11 of Part - C. (ii) Compaction of subgrade with power road roller etc. shall be carried out as an additional item as and when required. (iii) If required an additional item will

				be operated for loading sea sand from Puthuvypeen, transporting and dumping for the road formation and subgrade will be formed with red earth.

Sd/-
CHIEF ENGINEER